



# TEST REPORT

Send To: 1E481\*M  
CREEKSIDE SPRINGS, LLC  
667 MERCHANT STREET  
AMBRIDGE PA 15003  
Attn: MR. CHUCK WOZNAK

Customer: 1E480  
CREEKSIDE SPRINGS, LLC  
667 MERCHANT STREET  
AMBRIDGE PA 15003  
Attn: MR. CHUCK WOZNAK

Plant: 1E481  
CREEKSIDE SPRINGS, LLC  
32 WASHINGTON STREET  
SALINEVILLE OH 43945  
Attn: MR. JOE HARRIS

Product: Creekside Springs - Salineville-Facility # 1E481 - Creekside - Source  
Test Type: TO - Testing Only

Thank you for having your product tested by NSF.

The enclosed report details the result of the testing performed on your product. Your program representative will be contacting you in the near future if there are any remaining issues concerning the status of this product.

Please do not hesitate to contact us if you have any immediate questions pertaining to your product.

Reviewer:

Kurtis Kneen - Director, Chemistry Laboratory

Status: **Complete**

Program: 0195 - Beverages Program  
CC: Program Rep DEBORAH GLENN  
Region: 01 - Domestic  
PA Project: 9030432

**General Information**

Standard: USFDA - USFDA CFR Title 21 Part 165.110 Bottled Water

Clients Name for Product: Source Water  
 Date and Time Collected: 6/15/09 13:00 EDT  
 Sample Taken From: Sample Valve

Sample Id: **S-0000663395**

Description: Source Water 6/15/09 13:00 EDT

Sampled Date: 06/15/2009

Received Date: 06/16/2009

Testing Parameter	Detection Limit	Result	FDA SOQ	Units	P / F
<b>Physical Quality</b>					
Alkalinity as CaCO3	5	ND		mg/LCaCO3	
Color	5	ND	15	Color Unit	Pass
Specific Conductance	0.1	560		umhos/cm	
Corrosivity	0	-6.26			
Hardness, Total	2	180		mg/LCaCO3	
Odor, Threshold	1	1	3	TON	Pass
Solids Total Dissolved	5	350	500	mg/L	Pass
Turbidity	0.1	ND	5	NTU	Pass
pH	0.01	4.01			
Temperature	0	20		deg. C	
Bicarbonate	5	ND		mg/L HCO3	
<b>Disinfection Residuals/Disinfection By-Products</b>					
Chlorine, Total Residual	0.05	ND	4	mg/L	Pass
<b>Radiologicals</b>					
P1 Gross Alpha	3	ND	15	pCi/L	Pass
P1 Gross Beta	4	ND	50	pCi/L	Pass
Radium 226 by SM705 (modified)	1	ND		pCi/L	
Radium 228 by Ra-05	1	ND		pCi/L	
Total Radium	1	ND	5	pCi/L	Pass
Radon	200	ND		pCi/L	
Uranium	0.001	ND	0.03	mg/L	Pass
<b>Inorganic Chemicals</b>					
Aluminum	0.01	1.4	0.2	mg/L	Fail
Antimony	0.0005	ND	0.006	mg/L	Pass
Arsenic	0.002	ND	0.01	mg/L	Pass
* Asbestos in Water (Ref: EPA 600/4-83/043,100.1)					
Amphibole Fibers	0.2	ND		MFL	
Chrysotile Fibers	0.2	ND		MFL	
Single Fiber Detection Limit	0.2	ND		MFL	
Barium	0.001	0.016	2	mg/L	Pass
Beryllium	0.0005	0.0009	0.004	mg/L	Pass
Bromide	10	18		ug/L	
Cadmium	0.0002	ND	0.005	mg/L	Pass
Calcium	0.02	38		mg/L	
Chloride	2	42	250	mg/L	Pass
Chromium (includes Hexavalent Chromium)	0.001	ND	0.1	mg/L	Pass
Copper	0.001	0.002	1	mg/L	Pass

Sample Id: S-0000663395

Testing Parameter	Detection Limit	Result	FDA SOQ	Units	P / F
<b>Inorganic Chemicals</b>					
Cyanide, Total	0.01	ND	0.1	mg/L	Pass
Fluoride	0.1	0.1	2.4	mg/L	Pass
Iron	0.02	0.09	0.3	mg/L	Pass
Lead	0.001	ND	0.005	mg/L	Pass
Magnesium	0.02	21		mg/L	
Manganese	0.001	0.38	0.05	mg/L	Fail
Mercury	0.0002	ND	0.002	mg/L	Pass
Nickel	0.001	0.026	0.1	mg/L	Pass
Nitrogen, Nitrate	0.05	0.45	10	mg/L N	Pass
Nitrogen, Nitrite	0.025	ND	1	mg/L N	Pass
Total Nitrate + Nitrite-Nitrogen	0.02	0.45	10	mg/L	Pass
Potassium	0.5	2.7		mg/L	
Selenium	0.002	ND	0.05	mg/L	Pass
Silver	0.001	ND	0.1	mg/L	Pass
Sodium	0.5	46		mg/L	
Sulfur, Sulfate	0.5	180	250	mg/L	Pass
Surfactants (MBAS)	0.2	ND		mg/L	Pass
Thallium	0.0002	0.0002	0.002	mg/L	Pass
Phenolics	0.001	ND	0.001	mg/L	Pass
Zinc	0.01	0.04	5	mg/L	Pass
<b>Organic Chemicals</b>					
Diquat (Ref: EPA 549.2)					
Diquat	0.4	ND	20	ug/L	Pass
Endothall (Ref. EPA 548.1) - (ug/L)					
Endothall	9	ND	100	ug/L	Pass
Glyphosate (Ref: EPA 547)					
Glyphosate	6	ND	700	ug/L	Pass
Perchlorate (Ref: EPA 314.0)					
Perchlorate	1	ND		ug/L	
2,3,7,8-TCDD (Ref: EPA 1613B)					
2,3,7,8-Tetrachlorodibenzo-p-dioxin	10	ND	30	pg/L	Pass
Carbamate Pesticides (Ref: 531.2)					
3-Hydroxycarbofuran	1	ND		ug/L	
Aldicarb	1	ND		ug/L	
Aldicarb sulfone	1	ND		ug/L	
Aldicarb sulfoxide	1	ND		ug/L	
Carbaryl	1	ND		ug/L	
Carbofuran	1	ND	40	ug/L	Pass
Methomyl	1	ND		ug/L	
Oxamyl	1	ND	200	ug/L	Pass
Herbicides (Ref: EPA 515.3)					
2,4,5-TP	0.2	ND	50	ug/L	Pass
2,4-D	0.1	ND	70	ug/L	Pass
Bentazon	0.2	ND		ug/L	
Dalapon	1	ND	200	ug/L	Pass
DCPA Acid Metabolites	0.2	ND		ug/L	
Dicamba	0.1	ND		ug/L	

Sample Id: S-0000663395

Testing Parameter	Detection Limit	Result	FDA SOQ	Units	P / F
<b>Organic Chemicals</b>					
Dinoseb	0.2	ND	7	ug/L	Pass
Pentachlorophenol	0.04	ND	1	ug/L	Pass
Picloram	0.1	ND	500	ug/L	Pass
Multicomponent Pesticides and PCBs (Ref: EPA 505)					
Chlordane	0.2	ND	2	ug/L	Pass
PCB 1016	0.3	ND	0.5	ug/L	Pass
PCB 1221	0.4	ND	0.5	ug/L	Pass
PCB 1232	0.4	ND	0.5	ug/L	Pass
PCB 1242	0.3	ND	0.5	ug/L	Pass
PCB 1248	0.2	ND	0.5	ug/L	Pass
PCB 1254	0.2	ND	0.5	ug/L	Pass
PCB 1260	0.3	ND	0.5	ug/L	Pass
Toxaphene	1	ND	3	ug/L	Pass
Semivolatile Organic Compounds (Ref: EPA 525.2)					
2,4 Dinitrotoluene	0.5	ND		ug/L	
2,6-Dinitrotoluene	0.5	ND		ug/L	
Alachlor	0.1	ND	2	ug/L	Pass
Aldrin	0.1	ND		ug/L	
Atrazine	0.2	ND	3	ug/L	Pass
Benzo(a)Pyrene	0.1	ND	0.2	ug/L	Pass
bis(2-Ethylhexyl)adipate	2	ND	400	ug/L	Pass
bis(2-Ethylhexyl)phthalate	2	ND		ug/L	
Butachlor	0.2	ND		ug/L	
Butylbenzylphthalate	2	ND		ug/L	
Di-n-butylphthalate	2	ND		ug/L	
Dieldrin	0.5	ND		ug/L	
Diethylphthalate	2	ND		ug/L	
Dimethylphthalate	2	ND		ug/L	
Endrin	0.1	ND	2	ug/L	Pass
EPTC	0.5	ND		ug/L	
Heptachlor	0.1	ND	0.4	ug/L	Pass
Heptachlor Epoxide	0.1	ND	0.2	ug/L	Pass
Hexachlorobenzene	0.1	ND	1	ug/L	Pass
Hexachlorocyclopentadiene	0.1	ND	50	ug/L	Pass
Lindane	0.1	ND	0.2	ug/L	Pass
Methoxychlor	0.1	ND	40	ug/L	Pass
Metolachlor	0.1	ND		ug/L	
Metribuzin	0.1	ND		ug/L	
Molinate	0.1	ND		ug/L	
p,p'-DDE (4,4'-DDE)	0.5	ND		ug/L	
Propachlor	0.1	ND		ug/L	
Simazine	0.2	ND	4	ug/L	Pass
Terbacil	0.5	ND		ug/L	
Volatiles: EDB and DBCP (Ref: EPA 504.1)					
1,2-Dibromo-3-Chloropropane (DBCP)	0.01	ND	0.2	ug/L	Pass
Ethylene Dibromide (EDB)	0.01	ND	0.05	ug/L	Pass

Testing Parameter	Detection Limit	Result	FDA SOQ	Units	P / F
<b>Miscellaneous</b>					
1,1,1,2-Tetrachloroethane	0.5	ND		ug/L	
1,1,1-Trichloroethane	0.5	ND	200	ug/L	Pass
1,1,2,2-Tetrachloroethane	0.5	ND		ug/L	
1,1,2-Trichloroethane	0.5	ND	5	ug/L	Pass
1,1-Dichloroethane	0.5	ND		ug/L	
1,1-Dichloroethylene	0.5	ND	7	ug/L	Pass
1,1-Dichloropropene	0.5	ND		ug/L	
1,2,3-Trichlorobenzene	0.5	ND		ug/L	
1,2,3-Trichloropropane	0.5	ND		ug/L	
1,2,3-Trimethylbenzene	0.5	ND		ug/L	
1,2,4-Trichlorobenzene	0.5	ND	70	ug/L	Pass
1,2,4-Trimethylbenzene	0.5	ND		ug/L	
1,2-Dichlorobenzene	0.5	ND	600	ug/L	Pass
1,2-Dichloroethane	0.5	ND	5	ug/L	Pass
1,2-Dichloropropane	0.5	ND	5	ug/L	Pass
1,3,5-Trimethylbenzene	0.5	ND		ug/L	
1,3-Dichlorobenzene	0.5	ND		ug/L	
1,3-Dichloropropane	0.5	ND		ug/L	
1,4-Dichlorobenzene	0.5	ND	75	ug/L	Pass
2,2-Dichloropropane	0.5	ND		ug/L	
2-Chlorotoluene	0.5	ND		ug/L	
4-Chlorotoluene	0.5	ND		ug/L	
Benzene	0.5	ND	5	ug/L	Pass
Bromobenzene	0.5	ND		ug/L	
Bromochloromethane	0.5	ND		ug/L	
Bromodichloromethane	0.5	ND		ug/L	
Bromoform	0.5	ND		ug/L	
Bromomethane	0.5	ND		ug/L	
Carbon Tetrachloride	0.5	ND	5	ug/L	Pass
Chlorobenzene	0.5	ND	100	ug/L	Pass
Chlorodibromomethane	0.5	ND		ug/L	
Chloroethane	0.5	ND		ug/L	
Chloroform	0.5	ND		ug/L	
Chloromethane	0.5	ND		ug/L	
cis-1,2-Dichloroethylene	0.5	ND	70	ug/L	Pass
cis-1,3-Dichloropropene	0.5	ND		ug/L	
Dibromomethane	0.5	ND		ug/L	
Dichlorodifluoromethane	0.5	ND		ug/L	
Ethyl Benzene	0.5	ND	700	ug/L	Pass
Hexachlorobutadiene	0.5	ND		ug/L	
Isopropylbenzene (Cumene)	0.5	ND		ug/L	
m+p-Xylenes	1	ND		ug/L	
Methyl-tert-Butyl Ether (MTBE)	0.5	ND		ug/L	
Methylene Chloride	0.5	ND	5	ug/L	Pass
n-Butylbenzene	0.5	ND		ug/L	

Sample Id: S-0000663395

Testing Parameter	Detection Limit	Result	FDA SOQ	Units	P / F
<b>Miscellaneous</b>					
n-Propylbenzene	0.5	ND		ug/L	
Naphthalene	0.5	ND		ug/L	
o-Xylene	0.5	ND	10000	ug/L	Pass
p-Isopropyltoluene (Cymene)	0.5	ND		ug/L	
sec-Butylbenzene	0.5	ND		ug/L	
Styrene	0.5	ND	100	ug/L	Pass
tert-Butylbenzene	0.5	ND		ug/L	
Tetrachloroethylene	0.5	ND	5	ug/L	Pass
Toluene	0.5	ND	1000	ug/L	Pass
Total Trihalomethanes	0.5	ND	80	ug/L	Pass
Total Xylenes	0.5	ND	10000	ug/L	Pass
trans-1,2-Dichloroethylene	0.5	ND	100	ug/L	Pass
trans-1,3-Dichloropropene	0.5	ND		ug/L	
Trichloroethylene	0.5	ND	5	ug/L	Pass
Trichlorofluoromethane	0.5	ND		ug/L	
Trichlorotrifluoroethane	0.5	ND		ug/L	
Vinyl Chloride	0.5	ND	2	ug/L	Pass

**<<Additional Information>>**

Sample Id: S-0000663395

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
<b>Physical Quality</b>			
* Alkalinity (Ref: SM 2320-B)	16-JUN-2009		
<b>Test Notes</b> 6/19/09 kjones. Due to low pH of 4.01 unable to determine the alkalinity.			
* Color (Ref: SM 2120-B)	16-JUN-2009	14:30	
Specific Conductance (Ref: EPA 120.1)	16-JUN-2009		
* Corrosivity (Ref: SM 2330-B)			
* Hardness, Total (Ref: EPA 200.7)	17-JUN-2009		
* Odor, Threshold Number (Ref: EPA 140.1)	16-JUN-2009		
* Solids, Total Dissolved (Ref: SM 2540-C)	17-JUN-2009		
Turbidity (Ref: EPA 180.1)	16-JUN-2009	14:20	
pH (Ref: EPA 150.1)	16-JUN-2009	10:30	
* Bicarbonate (Ref: SM 2320-B)			
<b>Disinfection Residuals/Disinfection By-Products</b>			
* Chlorine, Total Residual (Ref: SM 4500-CL-G)	16-JUN-2009	14:40	
<b>Radiologicals</b>			
(1) * Gross Alpha/Beta Counts (Ref: EPA 900)- General Engineering	23-JUN-2009		
(1) * Total Radium (General Engineering)	26-JUN-2009		
(1) * Radon in Drinking Water, EPA 600/2-87/082, AppB (General Engineering Laboratories, Inc.)	18-JUN-2009		
Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
<b>Inorganic Chemicals</b>			
Aluminum (Ref: EPA 200.8)	17-JUN-2009		
Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
(2) * Asbestos in Water (Ref: EPA 600/4-83/043,100.1)	25-JUN-2009	1317	
Barium in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
Bromide (Ref: EPA 300.1)	23-JUN-2009		
Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)	17-JUN-2009		
Chloride (Ref: EPA 300.0)	16-JUN-2009		
Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
Copper in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
Cyanide, Total (Ref: EPA 335.4)	18-JUN-2009		
Fluoride (Ref: SM 4500-F-C)	18-JUN-2009		

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
<b>Inorganic Chemicals</b>			
Iron in Drinking Water by ICPAES (Ref: EPA 200.7)	17-JUN-2009		
Lead in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)	17-JUN-2009		
Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
Nitrogen, Nitrate (Ref: EPA 300.0)	16-JUN-2009	1140	
Nitrogen, Nitrite (Ref: EPA 300.0)	16-JUN-2009	1508	
Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)			
Potassium by ICPAES (Ref: EPA 200.7)	17-JUN-2009		
Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
Silver in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)	17-JUN-2009		
Sulfur, Sulfate (Ref: EPA 300.0)	16-JUN-2009		
* Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)	16-JUN-2009	11:05	
Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
Phenolics, Total Recoverable (Ref: EPA 420.2)	22-JUN-2009		
Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)	17-JUN-2009		
<b>Organic Chemicals</b>			
Diquat (Ref: EPA 549.2)	19-JUN-2009		19-JUN-2009
Endothall (Ref: EPA 548.1) - (ug/L)	16-JUN-2009		16-JUN-2009
Glyphosate (Ref: EPA 547)	23-JUN-2009		
Perchlorate (Ref: EPA 314.0)	17-JUN-2009		
2,3,7,8-TCDD (Ref: EPA 1613B)	24-JUN-2009		24-JUN-2009
Carbamate Pesticides (Ref: 531.2)	17-JUN-2009		
Herbicides (Ref: EPA 515.3)	17-JUN-2009		17-JUN-2009
Multicomponent Pesticides and PCBs (Ref: EPA 505)	23-JUN-2009		
Semivolatile Organic Compounds (Ref: EPA 525.2)	18-JUN-2009		17-JUN-2009
Volatiles: EDB and DBCP (Ref: EPA 504.1)	25-JUN-2009		
<b>Miscellaneous</b>			
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)	16-JUN-2009		

**Job Notes:**

Sample for Bromide testing taken at 6/18/09 at 09:00AM EDT and received at 52F (11 degrees C).

Asbestos was filtered past the 48 hour holding time.

Source water exceeds FDA limit for Aluminum and Manganese.

**Testing Laboratories:**

	Flag	Id	Address
All work performed at: (Unless otherwise specified)	→	NSF_AA	NSF INTERNATIONAL 789 N. DIXBORO ROAD ANN ARBOR MI 48105
	(1)	GENENG	GEL Laboratories LLC 2040 Savage Road Charleston, SC 29407 NELAP PA certificate number 68-000485 Arizona License #AZ0668
	(2)	BVNA	Bureau Veritas North America 22345 Roethel Dr. Novi, MI 48375 Arizona License #AZ0675

**References to Testing Procedures:**

NSF Reference	Parameter / Test Description
C0185	* Total Radium (General Engineering)
C1010	* Odor, Threshold Number (Ref: EPA 140.1)
C2015	2,3,7,8-TCDD (Ref: EPA 1613B)
C3012	* Asbestos in Water (Ref: EPA 600/4-83/043,100.1)
C3013	Chloride (Ref: EPA 300.0)
C3014	Bromide (Ref: EPA 300.1)
C3016	Nitrogen, Nitrate (Ref: EPA 300.0)
C3017	Nitrogen, Nitrite (Ref: EPA 300.0)
C3018	Sulfur, Sulfate (Ref: EPA 300.0)
C3019	Cyanide, Total (Ref: EPA 335.4)
C3021	Phenolics, Total Recoverable (Ref: EPA 420.2)
C3033	Aluminum (Ref: EPA 200.8)
C3036	Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)
C3039	Barium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3042	Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3044	Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3047	Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3053	Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3059	Copper in Drinking Water by ICPMS (Ref: EPA 200.8)
C3064	Iron in Drinking Water by ICPAES (Ref: EPA 200.7)
C3072	Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)
C3079	Potassium by ICPAES (Ref: EPA 200.7)
C3085	Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3086	Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)
C3091	Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3094	Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)
C3101	Lead in Drinking Water by ICPMS (Ref: EPA 200.8)
C3114	Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)
C3116	Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3128	Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3136	Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)
C3144	* Solids, Total Dissolved (Ref: SM 2540-C)
C3145	Turbidity (Ref: EPA 180.1)
C3155	* Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)
C3157	* Color (Ref: SM 2120-B)
C3158	Specific Conductance (Ref: EPA 120.1)
C3159	pH (Ref: EPA 150.1)
C3161	* Hardness, Total (Ref: EPA 200.7)
C3166	* Bicarbonate (Ref: SM 2320-B)
C3167	* Chlorine, Total Residual (Ref: SM 4500-CL-G)
C3170	Fluoride (Ref: SM 4500-F-C)
C3174	* Alkalinity (Ref: SM 2320-B)

References to Testing Procedures: ( Cont'd )

NSF Reference	Parameter / Test Description
C3188	Silver in Drinking Water by ICPMS (Ref: EPA 200.8)
C3198	* Radon in Drinking Water, EPA 600/2-87/082, AppB (General Engineering Laboratories, Inc.)
C3210	* Corrosivity (Ref: SM 2330-B)
C3244	* Gross Alpha/Beta Counts (Ref: EPA 900)- General Engineering
C3342	Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)
C4076	Carbamate Pesticides (Ref: 531.2)
C4145	Diquat (Ref: EPA 549.2)
C4154	Endothall (Ref: EPA 548.1) - (ug/L)
C4193	Glyphosate (Ref: EPA 547)
C4202	Herbicides (Ref: EPA 515.3)
C4292	Multicomponent Pesticides and PCBs (Ref: EPA 505)
C4343	Semivolatile Organic Compounds (Ref: EPA 525.2)
C4411	Volatiles: EDB and DBCP (Ref: EPA 504.1)
C4496	Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)
C4497	Perchlorate (Ref: EPA 314.0)
C4661	Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)

Certifications:

Michigan ( # 0048 )	Florida ( # E-87752 FL )	California ( # 01149 CA )
New York ( # 11206 )	Connecticut ( # PH-0625 )	New Jersey ( # 62770 )
South Carolina ( # 81005 )	Pennsylvania ( # 68-00312 )	Arizona ( # AZ0655 )
Hawaii	Indiana	Maryland ( # 201 )
Nevada ( # MI000302007A )	Virginia ( # 00045 )	Vermont ( # VT 11206 )

Test descriptions preceded by an asterisk "\*" indicate that testing has been performed per NSF International requirements but is not within its scope of accreditation.

Notes:

- 1) Bottled water sold in the United States shall not contain Fluoride in excess of the levels published by the USFDA in 21 CFR Part 165.110. These levels are based on the annual average of maximum daily air temperatures at the location where the bottled water is sold at retail. Please refer to the most current edition of the regulation to determine the Fluoride maximum level that pertains to your product.
- 2) A blank on the FDA SOQ column indicates that no maximum level has been established by the FDA for that contaminant.
- 3) An ND result means that the contaminant was not detected at or above the detection limit for the instrument.